



Product Service

CERTIFICATE

No. Z2 117850 0003 Rev. 00

Holder of Certificate: Omnis Power USA Inc
100N Howard St
Spokane WA 99201
USA

Certification Mark:



Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262218801-00

Valid until: 2027-08-04

Date, 2022-10-24

(Zhulin Zhang)



CERTIFICATE

No. Z2 117850 0003 Rev. 00

Model(s): OPxxxM72-P3-BF, xxx=520 to 555 in step of 5,
 OPxxxM60-P3-BF, xxx=430 to 465 in step of 5,
 OPxxxM54-P3-BF, xxx=390 to 415 in step of 5,
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed,double glass with Junction box,Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class A or C according to UL790

Tested according to:

- IEC 61215-1:2016
- IEC 61215-1-1:2016
- IEC 61215-2:2016
- IEC 61730-1:2016
- IEC 61730-2:2016
- EN 61215-1:2016
- EN 61215-1-1:2016
- EN 61215-2:2017
- EN IEC 61730-1:2018
- EN IEC 61730-1:2018/AC:2018-06
- EN IEC 61730-2:2018
- EN IEC 61730-2:2018/AC:2018-06