



Product Service

Attestation of Conformity

No. N8A 117850 0004 Rev. 00

Holder of Certificate: **Omnis Power USA Inc**
100N Howard St
Spokane WA 99201
USA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062258701-00

Date, 2022-10-24

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 117850 0004 Rev. 00

Model(s): OPxxxM72-P3-BF, xxx=520 to 555 in step of 5,
 OPxxxM60-P3-BF, xxx=430 to 465 in step of 5,
 OPxxxM54-P3-BF, xxx=390 to 415 in step of 5,
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed,double glass with Junction box,Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class A or C according to UL790

Tested according to: EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06